DIGITUS® DIGITUS □□□□□□□ □□□□ □□□□□ Unique - 600 □□ x 100

DN-19 26U-6/10-B-1

EAN 4016032377962



26U network rack, Unique 1342x600x1000 mm, color black (RAL 9005)

□□□□□□□ □□□□□ DIGITUS □□□□□ Unique □□□□□□□□□□□□ □ □□□□□□□□□□□□ □□□□ □□□□□□□□□□□□□□□□ □□□□□□□□□□ □ □□□□□□□□ □□□□□□□□ □□□□□□□ □□□□□ □ □□□□□□□□□□ □□□□□□□□□□□□□□□□□ □□□□□□□□□□. □□□□□□□□□□□□ □□□□□□□□□□□□□□□ □□□□□□□□□□□□□□□ □□ □□□□□□□□ □□□□□□□□□□□ □ □□□□□□ □□□□□□□□□□□□ □ 1000 □□. □□□□□□□□□□□□□□ □□□□□□ - □□□□□□ (RAL 7035) □ □□□□□□□□ (RAL 9005); □□□□□□□□□□□□□ □ □□□□□□□□ □□□□□ □□ □□□□□□□□□.

**□□□□□ DIGITUS® Unique □□□□□□□□□□□□□ □ □□□□□□□ □□□□□□□□ □□□□□□□□□□□□ □ □□□□□□□□□□□□□□□□□

More images:











Safety notes

- Ensure adequate ventilation to prevent the installed devices from overheating.
- Network cabinets should not be overfilled and the ventilation openings must not be blocked.
- Cables should be neatly routed and organized in cable ducts or trays.
- Use surge protection devices to protect sensitive devices from power surges or lightning strikes.
- Avoid moisture or wetness while observing the respective IP protection class.
- Ensure that the cabinet and the devices used are properly earthed.
- In regions with frequent thunderstorm activity, professional lightning protection should be integrated into the power supply.
- To avoid uneven loading, always mount the heaviest units at the bottom of the cabinet.
- Disconnect the installed devices from the power supply during maintenance or installation work.

EU responsible person

EU based economic operator ensuring the product complies with the required regulations.

ASSMANN Electronic GmbH
Auf dem Schüffel 3
Lüdenscheid, Germany
https://www.assmann.com
info@assmann.com